

# DIN-DVGW type examination certificate

## DIN-DVGW-Baumusterprüfzertifikat

**NW-6201CL0455**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	AB Valves GmbH Borsigallee 16, D-60388 Frankfurt
<b>Distributor</b> <i>Vertreiber</i>	AB Valves GmbH Borsigallee 16, D-60388 Frankfurt
<b>Product Category</b> <i>Produktart</i>	valves for water supply : butterfly valve (6201)
<b>Product Description</b> <i>Produktbezeichnung</i>	butterfly valve with flange connection for the drinking water supply
<b>Model</b> <i>Modell</i>	AB-Flansch-Absperrklappe
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: A0 001/10 from 21.12.2010 (TZW) KTW testing: 111A07 from 19.09.2007 (TZW) hygienic testing: 353A07_01 from 12.10.2007 (TZW) KTW testing: 246A06_2 from 29.12.2006 (TZW) hygienic testing: 348A07_01 from 11.10.2007 (TZW) KTW testing: 126A06_2 from 14.06.2006 (TZW)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DVGW W 363 (01.06.2010) DIN EN 1074-1 (01.07.2000) DIN EN 1074-2 (01.07.2004) BGA KTW (07.01.1977) DVGW W 270 (01.11.2007)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / Aktenzeichen</i>	21.12.2015 / 10-0079-WNE

26.01.2011 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - accredited by Deutsche Akkreditierungsstelle Technik (DATech) in the TGA GmbH for conformity assessment of products of gas and water supply

DVGW CERT GmbH - von der Deutschen Akkreditierungsstelle Technik (DATech) in der TGA GmbH akkreditiert für die Konformitätsbewertung von Produkten der Gas- und Wasserversorgung



DVGW CERT GmbH  
Josef-Wirmer-Straße 1-3  
53123 Bonn

Telefon: +49 228 91 88-888  
Telefax: +49 228 91 88-993  
eMail: info@dvw-cert.com

DAT-ZE-009/96-02



<b>Type Typ</b>	<b>Technical Data Technische Daten</b>	<b>Remarks Bemerkungen</b>
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 80	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 100	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 125	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 150	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 200	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 250	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 300	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 350	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 400	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 450	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 500	
AB-Flansch-Absperrklappe	pressure rating: PN 10/16 nominal diameter: DN 600	

#### Hints of Utilization / Remarks

##### Verwendungshinweise / Bemerkungen

With the test report W-148264-07-SI, date: 26.04.2006 (WHY) it is proven, that the requirements according the standard DVGW W270 (01.11.2007) appendix A.1.1: "Material for the standard application in contact with potable water" are fulfilled. With the following test reports it is proven, that the requirements according the standard DVGW W270 (01.11.2007) appendix A.1.3: "Test reports acc. DVGW W 270 (01.11.1999) for the range of application large-scale seals (D1) and small-scale seals (D2)" are fulfilled:

353A07\_01, date: 12.10.2007 (TZW) for the range of application D1 and D2

348A07\_01, date: 11.10.2007 (TZW) for the range of application D1 and D2